

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Split type air conditioner
Name and address of the applicant	Gree Electric Appliances, Inc. of Zhuhai West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070
Name and address of the manufacturer	Gree Electric Appliances, Inc. of Zhuhai West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Gree Electric Appliances, Inc. of Zhuhai West Jinji Rd, Qianshan, Zhuhai, Guangdong, China, 519070
Ratings and principal characteristics	220-240V~, 50/60Hz, 3200W, R32, IPX4 for outdoor unit, Class I
Trademark / Brand (if any)	GREE
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	Indoor unit: GFH36ACXF-S6DNE3C/I, GKH36ECXF-S6DNF6C/I, GTH36CBXF-S6DNA1C/I Outdoor unit: GFH36ACXF-S6DNE3D/O
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60335-2-40:2018 IEC 60335-1:2010 + A1:2013 + A2:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	250922266GZU-001

This CB Test Certificate is issued by the National Certification Body

Intertek Testing Services (Singapore) Pte Ltd  
5, Pereira Road, #06-01  
Asiawide Industrial Building  
Singapore 368025

intertek

Date: 14 November 2025

Signature:

Ong Keng Chuan

