

Otorgada según los requisitos establecidos por la Res. Ministerio de Economía, Secretaría de Industria y Comercio N°237/24, Res. N°16/25 sus anexas y complementarias, al(los) producto(s) cuyas características se detallan a continuación.

Este Certificado será válido por un plazo de 2 años a partir de la fecha de su emisión, luego del cual deberá presentarse juntamente con una constancia de seguimiento de producto en el mercado según las Resoluciones previamente indicadas.

Granted according to the product requirements established by the Res. Ministry of Economy, Secretariat of Industry and Commerce N°237/24, Res. N°16/25 their annexes and complementary provisions to the product(s) with the following characteristics.

This Certificate will be valid 2 years from the date of issuance, after that it must be presented along with a market surveillance evidence according to the previously indicated Resolutions.

CERTIFICADO DE TIPO (ESQUEMA 2 ISO/IEC 17067) - SEGURIDAD ELÉCTRICA

Type Certificate (Scheme 2 ISO/IEC 17067) - Electrical Safety

Producto	Cortina de Aire con Intercambiador de Agua.
Product	
Titular del Certificado / Dirección	Ansal Refrigeración S.A.
Certificate holder / Address	Otamendi 530, C.A.B.A., Argentina.
Fábrica / Dirección	Sonniger Spolka Akcyjna // Podolska 21, 81-321, Gdynia, Polonia.
Factory / address	
Características técnicas	230V~; 50 Hz; IP21; Clase I; 1) 2,31A; 2) 1,8A; 3) 1,4A.
Technical characteristics	
Marca Comercial	SONNIGER.
Trade mark	
Modelo o tipo	1) GUARD 200W 2) GUARD 150W 3) GUARD 100W.
Model or type	
Norma(s) aplicada(s)	IEC 60335-1: 2010 + A1: 2013 + A2: 2016 (Ed. 5.2) + IEC 60335-2-40: 2013 + A1: 2016 (Ed. 5.1).
Standard(s) used	
Informe(s) de ensayo / Emitido por	SE Nº 70256.
Test report / issued by	IADEV S.A
Fecha de emisión inicial	25/03/2025.
Date of first edition	
Observaciones	NA
Remarks	

Firma

Signature


Lic. Federico A. Cintolo
Responsable Técnico